



CORRIGENDUM # 2

**SUPPLY OF CNG STORAGE CASCADE FOR CGD PROJECT IN THE STATE OF TRIPURA
TENDER NO. - P.007798 R11050 008**

Date: 27.04.2017

Project: City Gas Distribution Project in Tripura

Owner: Tripura Natural Gas Company Ltd (TNGCL)

Pre-bid meeting date: 10.04.2017

Sr. No.	Description	Tender Page No.	Clause/ Para/ Section	Amendment/Addition/Modification/Deletion
Vol II of II				
1	Painting	200026	7.12, Para 2, Point 2, Page 10 of 15	Modification Please read the second bullet as : " Surface preparation by Shot Blasting as per grade SA 2 1/2, IS 9954 / ISO 8501. Three coats of paint shall be applied with minimum thickness of 300 micron. The recommended Painting system should be of Category C-1 Very high (Industrial) as specified in the Standard ISO 12944 Part 1 to 8. The proposed Painting system shall conform to Table A 5 of ISO 12944 – 5 Standard."
1	Mobile Storage Cascades	200026	8, Point 3, Page 10 of 15	Modification Please read the third bullet as : "Each cylinder of mobile cascades used for the transport of compressed natural gas shall be a type approved by the PESO/ COE"

Note: All other terms & conditions of tender document remain unaltered.

SK Gupta
TE

Amr
TE